



中国国家强制性产品认证证书

证书编号: 2003010307032485

委托人名称、地址

浙江正泰电器股份有限公司
浙江省乐清市北白象镇正泰工业园区正泰路1号

生产者(制造商)名称、地址

浙江正泰电器股份有限公司
浙江省乐清市北白象镇正泰工业园区正泰路1号

生产企业名称、地址

上海诺雅克电气有限公司
上海市松江区思贤路3857号

产品名称和系列、规格、型号

塑料外壳式断路器
NM8-100S, NM8-100H, NM8-100R; 详见参数附件

产品标准和技术要求

GB 14048.2-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2015年10月23日

有效期至: 2020年02月13日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2003年03月05日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 1248337



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2003010307032485

NAME AND ADDRESS OF THE APPLICANT

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang, Yueqing, Zhejiang
Province, P. R. China

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang, Yueqing, Zhejiang
Province, P. R. China

NAME AND ADDRESS OF THE FACTORY

NOARK Electrics (Shanghai) Co., Ltd.
No.3857 Sixian Road, Songjiang Industrial Zone, Shanghai, P. R. China

NAME, MODEL AND SPECIFICATION

Moulded Case Circuit-breaker
NM8-100S, NM8-100H, NM8-100R; See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.2-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-C03-02:2014).

Date of issue: Oct. 23, 2015 Date of expiry: Feb. 13, 2020

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Mar. 05, 2003

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

Q 1248337



中国国家强制性产品认证证书

附录:

第 1 页 共 1 页

证书编号: 2003010307032485

纸号: 1248337

NM8-100S, NM8-100H, NM8-100R

In: 16A, 20A, 25A, 32A, 40A, 63A, 80A, 100A;

Ue: AC400V/690V, DC250V(单极), DC500V(两极串)

过电流脱扣型式: 电磁式

Ue=AC400V 时: S 型: $I_{cs}=I_{cu}=50kA$, H 型: $I_{cs}=I_{cu}=100kA$, R 型: $I_{cs}=I_{cu}=125kA$;

Ue=AC690V 时: S 型: $I_{cs}=I_{cu}=8kA$, H 型: $I_{cs}=I_{cu}=10kA$, R 型: $I_{cs}=I_{cu}=20kA$;

Ue=DC250V(单极)/DC500V(两极串) 时: $I_{cs}=I_{cu}=50kA$;

使用类别: A 类; 极数: 2P, 3P, 4P

注: 此附录与证书同时使用时有效。



主任: 

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

